

|                               |   |              |
|-------------------------------|---|--------------|
| BNPM/LTE/MCS<br>/0540/2020-21 | BANK NOTE PAPER MILL INDIA PRIVATE LIMITED  |              |
|                               | CORRIGENDUM No. 3<br>Supply of 3Phase Metal Clad Socket-63Amps at BNPM<br>Plant, Mysuru | Sheet 1 of 2 |

**CORRIGENDUM No. 3 DATED 09.10.2020**

**FOR**

**TENDER No.**

**BNPM/LTE/MCS/0540/2020-21 DATED 28.08.2020**

**FOR**

**Supply of 3Phase Metal Clad Socket-63Amps at BNPM Plant, Mysuru**

**PURCHASER : BANK NOTE PAPER MILL INDIA PRIVATE LIMITED**

**MATERIAL : METAL CLAD SOCKET - 63Amps**

**LOCATION : BNPM PLANT, MYSURU, KARNATAKA**



|                               |   |              |
|-------------------------------|---|--------------|
| BNPM/LTE/MCS<br>/0540/2020-21 | BANK NOTE PAPER MILL INDIA PRIVATE LIMITED  |              |
|                               | CORRIGENDUM No. 3<br>Supply of 3Phase Metal Clad Socket-63Amps at BNPM<br>Plant, Mysuru | Sheet 2 of 2 |

### 1.0 SCOPE OF THIS CORRIGENDUM

1. Details provided in this corrigendum shall override those mentioned in the tender no. BNPM/LTE/MCS/0540/2020-21 Dated: 28.08.2020.

2. Except for details mentioned herein, all other details contained in the tender no. BNPM/LTE/MCS/0540/2020-21 Dated: 28.08.2020 shall remain unchanged.

### 3. Due date of bid submission:

|   |                       |
|---|-----------------------|
| Closing date and time for receipt of tenders      | 16.10.2020; 1430 Hrs. |
| Time and date of opening of techno-commercial bid | 16.10.2020; 1500 Hrs. |

### 4. Inclusions/Clarifications through this corrigendum:

| Sl. No. | As per Tender Clause   | Action/Clarification incorporated in this Corrigendum  |
|---------|--|--|
| 1       | <p><b><u>Section VII: Technical Specifications {Page no. 31 of 51}</u></b></p> <p>5. Metal Clad Socket (Top Entry) with 63A/30mA RCBO</p> <p>6. Enclosure Box: Metal</p> <p><b><u>Bidder Queries:</u></b></p> <p>(a) Instead of Metal Clad Enclosure, can we use CRCA Sheet Enclosure.</p> | <p>(a) Any make of Metal enclosure is acceptable, provide the material used is CRCA sheet of min. 2mm thickness with Powder coated RAL-7032, Texture finish.</p> |

