

BNPM/OTE/132/2026-27 dated 14.07.2026	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 1 OF 10
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

CORRIGENDUM No. 1, DATED 14.08.2026

FOR

TENDER NO. BNPM/OTE/132/2026-27 dated 14.07.2026

**TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF
DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU.**



BNPM/OTE/132/2026-27 dated 14.07.2026	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 2 OF 10
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

1.0 SCOPE OF THIS CORRIGENDUM

- 1.1 This corrigendum dated 14.08.2026 is issued for clarification, amendment and extension of bid submission due date and amendment to tender terms.
- 1.2 Except for details mentioned herein, all other details contained in the tender no. BNPM/OTE/132/2026-27 dated 14.07.2026, shall remain applicable and unchanged.

1. AMENDMENT TO TENDER TERMS

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
1	Sec VI: LOR: Completion period:	To extend the project delivery timeline upto 7 months.	The entire work as per the scope of work including supply, installation, commissioning are to be completed within 5 months from the date of issuance of order/LOA (whichever is issued earlier).	The entire work as per the scope of work including supply, installation, commissioning are to be completed within 7 months from the date of issuance of order/LOA (whichever is issued earlier).
2	Sec VII, Technical Specification &	Shutdown time of 2 days (48 Hrs) per Dynamic Volage Sag	Commissioning shall be carried out only after the shutdown clearance	One day shutdown shall be provided per system on a mutually agreed date ,



BNPM/OTE/132/2026-27 dated 14.07.2026		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED			SHEET 3 OF 10
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1			
Sl. No.	Tender Clause	Pre-bid query	Existing tender terms	Amendment to the tender terms	
	Scope of Work: Detailed Scope of Work, Clause 3.10	Corrector system is required to be provided along with site readiness and shutdown to be given within 4 weeks against supply.	from procuring entity.	preferably on planned holidays. Erection & installation including cable laying shall be done parallelly. Only for energizing/ commissioning one day shutdown shall be provided. Note: Suitable contract period extension without any price escalation may be provided for any delay pertaining to procuring entity, this is to be read along with <i>Sec IV: GCC: Clause 23: Delay in the supplier's performance.</i>	
3	Sec VII, Technical Specification & Scope of Work:	Current rating of the 400 A Dynamic Voltage Sag Corrector (DVR). Standard	Current Rating Capacity: 400 A.	Current Rating Capacity: 400 A (±) 10A.	



BNPM/OTE/132/2026-27 dated 14.07.2026		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED		SHEET 4 OF 10
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1		
<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
	Sr No. 6; Technical Specification of Voltage Sag Corrector	system specification is 415 V, 280 kVA, 60% voltage correction ($\pm 10\%$ continuous correction), which results in a DVR current rating of approximately 390 A instead of 400 A.		
4	Sec VII, Technical Specification & Scope of Work: Sr No. 6; Technical Specification of Voltage Sag Corrector	Input Voltage - 415($\pm$)10%. Being a global product, operating voltage is 400($\pm$) 20%.	Voltage: 415 V AC +/- 10%	As per tender.



BNPM/OTE/132/2026-27 dated 14.07.2026		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED			SHEET 5 OF 10
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1			
<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>	
5	SCC, Sec V: SCC, Clause 13(a,b,c): Terms & Mode of Payment:	The payment terms are requested as per the terms of GCC and not of SCC.	a) Main product: i) 60% of the order value excluding the value for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after receipt and acceptance of supply at BNPMIPL, Mysore and on submission of invoice. ii) 40% of the order value excluding the value for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released	a) Main product: i) 70% of the order value excluding the value for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after receipt and acceptance of supply at BNPMIPL, Mysore and on submission of invoice. ii) 30% of the order value excluding the value for laying 3C x 240 Sq.mm Cu Armoured Cable shall be released within 30 days after completion of installation, commissioning as per scope of work, against certification by competent	



BNPM/OTE/132/2026-27 dated 14.07.2026	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 6 OF 10
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
			within 30 days after completion of installation, commissioning as per scope of work, against certification by competent authority appointed by Procuring Entity and on submission of invoice.	authority appointed by Procuring Entity and on submission of invoice.

2.0 CLARIFICATION TO THE TENDER:

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Action/Clarification</u>
1	Sec III, SIT, Clause Sl No. 7: Earnest Money Deposit (EMD)	Whether a service provider is eligible for EMD exemption.	Yes, for MSEs having major activity as "Service Providers" as per UDYAM certificate. Refer Sr No. 7, Pg No. 16.



BNPM/OTE/132/2026-27 dated 14.07.2026		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED		SHEET 7 OF 10
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1		
Sl. No.	Tender Clause	Pre-bid query	Action/Clarification	
2	Sec IX, Qualification/Eligibility Criteria Experience, Past Performance:	a) OEM reference may be accepted. b) Whether OEM qualification documents can be submitted / used for authorized partners. c) If the bidder is an authorised representative of OEM: The bidder himself should have been associated, as the authorised representative with the "Same OEM" or "Other OEM" for past three years ending on 31.03.2026 for the supply of "Similar type of product" and The OEM (himself or through authorised representatives) should have regularly for past three years ending 31.03.2026 manufactured and supplied "Similar type of product". May be clarified.	a), b) As per tender terms. May refer corresponding tender clause. c) Association of the bidder being authorised representative for the supply of "Similar type of product" and the OEM being manufacturer & supplier of "Similar type of product" are to be substantiated through documentary evidence.	
3	Sec VII, Technical Specification & Scope of Work	Whether cost of earthing is to be included in the quotation.	Existing earthing system may be used.	



BNPM/OTE/132/2026-27 dated 14.07.2026		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 8 OF 10
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	
Sl. No.	Tender Clause	Pre-bid query	Action/Clarification
4	Sec VII, Technical Specification & Scope of Work	For cable laying whether existing cables can be used or cost of new cables are to be included in quotation.	As per tender terms.
5	Sec VII, Technical Specification & Scope of Work	Whether any additional civil or electrical work are required to be included in scope of work.	As per tender terms. Civil work is not in scope of bidder.
6	Sec VII, Technical Specification & Scope of Work	On which floor will the DVR be installed?	First or Second Floor of the building.
7	Sec VII, Technical Specification & Scope of Work	If the DVR HMI will be monitored through your SCADA/Monitoring System, kindly specify the approximate distance between the DVR installation location and the SCADA/Monitoring System.	Not applicable.
8	Sec VII, Technical Specification & Scope of Work, Sr	The dimension of the Voltage Sag Corrector should not be more than 2500mm x 800mm x 2400mm (W X D X H). Our DVR dimension is	Accepted



BNPM/OTE/132/2026-27 dated 14.07.2026		BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 9 OF 10
		TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	
Sl. No.	Tender Clause	Pre-bid query	Action/Clarification
	No. 4: Essential features of Dynamic Voltage Sag Corrector:	3530 X 731 X 2000mm. We can install DVR by separating main unit and bypass to accommodate space constraint. Confirmation is requested.	
9	Sec V, SCC, Clause Sl No. 4: Warranty & Support	As per tender terms: The System supplied shall remain under on-site warranty of OEM for a period of 1 Year from the date of completion of commissioning. This clause is to be read along with GCC clause 16. Note: OEM to ensure technical support & spares for the system to be supplied for a minimum period of five years after date of completion of successful commissioning. Query: OEM meeting the criteria.	As per tender terms.
10	Sec VII, Technical Specification & Scope of Work	Confirmation is requested for the earthing system available at your facility (e.g., TN-C, TN-S, TN-C-S, or any other system). Also, please confirm that the required earthing points for the	TN-S system, existing earthing bus is available near to the proposed voltage sag corrector panel location. Bidder has to connect the same with panel as



BNPM/OTE/132/2026-27 dated 14.07.2026	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SHEET 10 OF 10
	TENDER FOR SUPPLY, INSTALLATION, TESTING, COMMISSIONING OF DYNAMIC VOLTAGE SAG CORRECTOR AT BNPM PLANT, MYSURU. CORRIGENDUM NO. 1	

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Pre-bid query</u>	<u>Action/Clarification</u>
		DVR installation will be provided at the site.	per applicable IS standards.
11	Sec V, SCC, Clause 14: Contract Price	Essential Spares are required with 3 years price validity from completion of warranty period. Since these are imported items, it is requested to give concession on Price validity to 2 years from date of supply.	As per tender terms.

3. REVISION OF TENDER:

<u>Sl. No.</u>	<u>Tender Clause</u>	<u>Existing tender terms</u>	<u>Amendment to the tender terms</u>
1	Due date & time for bid submission and bid opening:	Due date & time of bid submission: 04.08.2026, @ 11:00 hours. Tender opening due date & time: 04.08.2026, @ 11:30 hours	Due date & time of bid submission: 18.08.2026, @ 11:00 hours. Tender opening due date & time: 18.08.2026, @ 11:30 hours

