

BNPM/NCB/407/2024-25 dated 06.12.2024	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	Sheet 1 of 2
	CORRIGENDUM No. 1 SUPPLY , INSTALLATION AND COMMISSIONING OF PARALLEL REDUNDANT UPS SYSTEM WITH BATTERY BANK ALONG WITH NON COMPREHENSIVE AMC OF THREE (3) YEARS AT BANK NOTE PAPER MILL (BNPM), MYSURU.	

CORRIGENDUM No. 1 DATED 27.12.2024

FOR

TENDER No.

NATIONAL COMPETITIVE BIDDING No. BNPM/NCB/407/2024-2025 DT 06.12.2024

PURCHASER	:	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED
MATERIAL	:	SUPPLY , INSTALLATION AND COMMISSIONING OF PARALLEL REDUNDANT UPS SYSTEM WITH BATTERY BANK ALONG WITH NON COMPREHENSIVE AMC OF THREE (3) YEARS AT BANK NOTE PAPER MILL (BNPM), MYSURU.
LOCATION	:	BNPM PLANT, MYSURU, KARNATAKA



BNPM/NCB/407/2024-25 dated 06.12.2024	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	CORRIGENDUM No. 1 SUPPLY , INSTALLATION AND COMMISSIONING OF PARALLEL REDUNDANT UPS SYSTEM WITH BATTERY BANK ALONG WITH NON COMPREHENSIVE AMC OF THREE (3) YEARS AT BANK NOTE PAPER MILL (BNPM), MYSURU.	Sheet 2 of 2

1.0 SCOPE OF THIS CORRIGENDUM

1. Details provided in this corrigendum shall override those mentioned in the tender no. BNPM/NCB/407/2024-25 dated: 06.12.2024

2. Except for details mentioned herein, all other details contained in the tender no. BNPM/NCB/407/2024-25 dated: 06.12.2024 shall remain unchanged.

3. Due date of bid submission:

Closing date and time for receipt of tenders	10.01.2025; 1100 Hrs.
Time and date of opening of Techno Commercial bid	10.01.2025; 1130 Hrs.

1.

4. Amendment to tender

Sl. No.	Tender Section No	Bidders Query	BNPM Reply
1	Section-VI-List of Requirements under Brief Description of Goods, Point No 4	Supply of 12V 100Ah SMF battery bank along with battery rack for 2x20 KVA UPS including necessary DC cables.	Supply of 12V, SMF battery bank along with battery rack for 2x20 KVA UPS including necessary DC cables.
2	Section-VI-List of Requirements under Brief Description of Goods, Point No 5		Supply of 12V , SMF battery bank along with battery rack for 10 KVA UPS including



BNPM/NCB/407/2024-25 dated 06.12.2024	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	<p align="center">CORRIGENDUM No. 1</p> <p align="center">SUPPLY , INSTALLATION AND COMMISSIONING OF PARALLEL REDUNDANT UPS SYSTEM WITH BATTERY BANK ALONG WITH NON COMPREHENSIVE AMC OF THREE (3) YEARS AT BANK NOTE PAPER MILL (BNPM), MYSURU.</p>	Sheet 3 of 2

		Supply of 12V 42Ah SMF battery bank along with battery rack for 10 KVA UPS including DC necessary DC cables.	DC necessary DC cables.
3	Section-VI-List of Requirements under Brief Description of Goods, Point No 6	Supply of 12V, 42Ah SMF battery bank along with battery rack for 6 KVA UPS including DC necessary DC cables.	Supply of 12V , SMF battery bank along with battery rack for 6 KVA UPS including DC necessary DC cables.
4	Section-VII- Technical Specifications under 1)Bill of Material, point no 4	Supply of 12V 100Ah SMF battery bank along with battery rack for 2x20 KVA UPS including necessary DC cables.	Supply of 12V , SMF battery bank along with battery rack for 2x20 KVA UPS including necessary DC cables.
5	Section-VII- Technical Specifications under 1)Bill of Material, point no 5	Supply of 12V 42Ah SMF battery bank along with battery rack for 10 KVA UPS including DC necessary DC cables..	Supply of 12V ,SMF battery bank along with battery rack for 10 KVA UPS including DC necessary DC cables..
6	Section-VII- Technical Specifications under 1)Bill of Material, point no 6	Supply of 12V 42Ah SMF battery bank along with battery rack for 6 KVA UPS including DC necessary DC cables.	Supply of 12V ,SMF battery bank along with battery rack for 6 KVA UPS including DC necessary DC cables.



BNPM/NCB/407/2024-25 dated 06.12.2024	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	
	CORRIGENDUM No. 1 SUPPLY , INSTALLATION AND COMMISSIONING OF PARALLEL REDUNDANT UPS SYSTEM WITH BATTERY BANK ALONG WITH NON COMPREHENSIVE AMC OF THREE (3) YEARS AT BANK NOTE PAPER MILL (BNPM), MYSURU.	Sheet 4 of 2

7	Section-VII-Technical Specifications	Please confirm whether all earthing is within our scope or if we will receive dedicated earthing points	Earth connecting points shall be provided by BNPM, further extension to both UPS & Bus coupler panel shall in the scope of bidder.
8	Section-XI-Price Schedule Table no 01-Part A(Pages 60 and 61)	Please refer Price Schedule Part A	Please refer Annexure-1-attached
9	As per Tender	(Closing date & time for receipt of bids through E-portal) " Closing date and Time : 27.12.2024 ; 11.00 am Opening date and Time :27.12.2024 ;1130 am	Closing date & time : 10.01.2025; 11.00 am Opening Date and Time : 10.01.2025; 11.30 am



ANNEXURE-1 - REVISED PRICE SCHEDULE

Sch edu le No.	Description	UO M	Qu ant ity	HS N/ SA C	Part-A-Price for Supply & Installation & Commissioning (INR)								Effective total Price (net of input tax credit) (F.O.R Mysore) (INR)	
					Basic unit Price (INR)	Unit Installation Commissioning & Training Charges (INR)	Transportation , of man and materials, accommodation, n, Travelling, Fooding, Boarding and Lodging & any other charges(if any) per unit (INR)	Unit Price (incl. Transportation, of man and materials, accommodation , Travelling, Fooding, Boarding and Lodging & any other charges (if any) excl. of GST) (INR)	GST (%)	GST on Unit Price (INR)	Total Unit Price (incl. of GST) (INR)	Less: Input Credit (GST) (INR)		Effective Unit Price (net of input tax credit) (F.O.R Mysore) (INR)
					B	C	D	E=B+C+D	F	G=E*F	H=E+G	I	J=H-I	K=J*A
TO BE FILLED ONLINE IN E-TENDERING PORTAL ONLY														
1.	Supply of 2 x 20kVA Parallel Redundant UPS with Bus coupler DB, Battery Racks & DC Cables	Set	1											
2.	Supply of 2 x 10kVA Parallel Redundant UPS with Bus coupler DB, Battery Racks & DC Cables (1 set = 2nos)	Set	2											

TO BE FILLED ONLINE IN E-TENDERING PORTAL ONLY





TO BE FILLED ONLINE IN E-TENDERING PORTAL ONLY							
3.	Supply of 2 x 6kVA Parallel Redundant UPS with Bus coupler DB, Battery Racks & DC Cables (1 set = 2nos)	Set	2				
4.	Supply of 12V, SMF Battery bank for 2 x 20 KVA UPS	Set	2				
5.	Supply of 12V, SMF Battery bank for 2 x 10 KVA UPS	Set	4				
6.	Supply of 12V, SMF Battery bank for 2 x 6 KVA UPS	Set	4				
7.	Installation & Commissioning of Parallel Redundant UPS System	Lot	1				
Total effective price (net of input tax credit) for Supply, installation and commissioning of Parallel Redundant UPS system with battery bank (F.O.R – BNPM, Mysuru site) in Figures (INR)							
Total effective price (net of input tax credit) Supply, installation and commissioning of Parallel Redundant UPS system with battery bank (F.O.R – BNPM, Mysuru site) in Words (INR)							

