BANK NOTE PAPER MILL INDIA PRIVATE LIMITED BNPM/OTE/ 61/2023-24 CORRIGENDUM NO.1

CORRIGENDUM No.1, DATED 16.05.2023 FOR

TENDER NO. BNPM/OTE/61/2023-24 dated 09.05.2023 FOR SUPPLY OF LIGHTING SPARES AT BNPM PLANT, MYSURU

1.0 AMENDMENT TO TENDER:

Sl.	As per Tender	May be read as
<u>No.</u>		
	Section III: Sl No.4	Section III: Sl No.4
1.	 2x28W Electronic ballast, Equivalent to Bajaj-make BJHF228P for FTL 2x28W TL5 lamp and with similar mount to suit Bajaj-make BTHBX 428 fitting, Nominal voltage: 220-240 V ac, Power factor: 0.95 (minimum), Make: Bajaj/ Wipro/ Philips/ Osram/Havells/Crompton Greaves/Any equivalent 	 2x28W Electronic ballast, Equivalent to Bajaj-make BJHF228P for FTL 2x28W TL5 lamp and with similar mount to suit Bajaj-make BTHBX 428 fitting, Nominal voltage: 220-240 V ac, Power factor: 0.95 (minimum), Make: Bajaj/ Wipro/ Philips/ Osram/Havells/Crompton Greaves/Any equivalent



BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

BNPM/OTE/ 61/2023-24

TENDER FOR SUPPLY OF LIGHTING SPARES AT BNPM PLANT, MYSURU CORRIGENDUM NO.1

		The distance of the mounting hole for 28W Electronic Ballast will be 265 mm
Z.	 1X36W Electronic Ballast Operating Voltage Range 230 Volt Rated Power 36 Watt Frequency 50 HZ Input current - 0.16A/PF>=0.9 Material Of Enclosure Polycarbonate Ingress Protection Rating Of Enclosure (IP Rating) IP 65 Preferred Make: CG(EBN 136DN), Philips(Sumo Ultra), Wipro(Insta turbo) /Any equivalent 	 Section III: Sl No.5 1X36W Electronic Ballast Operating Voltage Range 230 Volt Rated Power 36 Watt Frequency 50 HZ Input current - 0.16A/PF>=0.9 Material Of Enclosure Polycarbonate Preferred Make: CG(EBN 136DN), Philips(Sumo Ultra), Wipro(Instaturbo) /Any equivalent

EXCEPT FOR DETAILS MENTIONED HEREIN, ALL OTHER DETAILS CONTAINED IN THE TENDER NO. BNPM/OTE/61/2023-24, dated: 09.05.2023, SHALL REMAIN SAME AND UNCHANGED.

