

BNPM/OTE/457/2025-26

Dated 07.01.2026

**BANK NOTE PAPER MILL INDIA PRIVATE LIMITED**

**ROOF RAIN WATER HARVESTING AT BNPM, MYSORE  
CORRIGENDUM NO. 5**

SHEET 1  
OF 2

**CORRIGENDUM No. 5, DATED 25.02.2026**

**FOR**

**TENDER NO. BNPM/OTE/0457/2025-26 dated 07.01.2026**

**FOR**

**PROVIDING ROOF RAIN WATER HARVESTING SYSTEM.**

**PURCHASER: BANK NOTE PAPER MILL INDIA PRIVATE LIMITED**

**LOCATION: MYSORE, KARNATAKA**



BNPM/OTE/457/2025-26

Dated 07.01.2026

**BANK NOTE PAPER MILL INDIA PRIVATE LIMITED**

**ROOF RAIN WATER HARVESTING AT BNPM, MYSORE  
CORRIGENDUM NO. 5**

SHEET 2 OF 2

**1.0 SCOPE OF THIS CORRIGENDUM**

1.1 This corrigendum issued to incorporate revision made in Tender for Providing Roof Rain water harvesting system for Pulp Mill, Work Shop, Boiler at BNPM, Mysuru. Details provided in this corrigendum shall override those mentioned in the Tender No. BNPM/OTE/0457/2025-26 dated 07.01.2026.

1.2 Except for details mentioned herein, all other details contained in the Tender no. BNPM/OTE/0457/2025-26 dated 07.01.2026, shall remain applicable and unchanged.

**2.0 REVISION TO THE TENDER:**

2.1

Closing date and time for receipt of tenders 04.03.2026 - 1100 Hours

Date and time of opening of Techno-commercial bid 04.03.2026 - 1130 Hours

**2.2 Amendment**

Sl no	Tender clause	Existing	To be read as/additional information	Reason
1	<b>Section -VI-List of Requirements</b>			
	As per Brief scope of work Sl no.1 (i)	Supply and fixing/installation of PVC pipes (Outer Dia 160mm, Schedule 80)	The MOC of the pipe shall follow IS 13592:2013. As per the standard, pipeline shall be UPVC Type A for rain water harvesting.	A few clarifications received from bidder.

