



बैंक नोट पेपर मिल इण्डिया प्रा. लिमिटेड

BANK NOTE PAPER MILL INDIA PVT LIMITED

JV of SPMCIL - A Govt. of India Enterprises & BRBNMPL - A Subsidiary of RBI

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

CIN: U21090KA2010PTC055475

CORPORATE OFFICE, MYSORE

gopalakrishnan.m@bnpmindia.com

Ph: 0821 2401 158

Limited Tender Enquiry No: BNPM/LTE/PROCESS INDICATOR/384/2018-19

Issuing Date: 20.10.2018 12:00 hrs.

Closing date: 30.10.2018 15:00 hrs.

1. Scope of work:

Supply of Panel Mounted Universal Input Process Indicator as per technical specifications.

2. Terms & Conditions:

S. No	Particulars	Quantity
1.	Payment Terms	100% payment within 30 days of receipt and acceptance of goods by the consignee at destination and on production of all required documents by the supplier.
2.	Price	Price should be inclusive of all taxes & duties.
3.	Freight	Shall be included in quoted price.
4.	Packing & Forwarding	Shall be included in quoted price.
5.	Delivery Terms	D.A.P, Bank Note Paper Mill India Private Limited, Mysore
6.	Warranty Period from date of supply at BNPM, Mysuru
7.	Warranty Certificate	Applicable / Not Applicable
8.	Delivery Period	2 weeks from date of receipt of purchase order
9.	Validity of Bid	30 days from closing date of tender including extensions (if any).
10.	Material to be delivered at	Engineering Stores, Bank Note Paper Mill India Private Limited, Note Mudran Nagar, Mysore 570 003.
11.	Contact person	Mr. Gopalakrishnan M P: 0821-2401158



Limited Tender Enquiry No: BNPM/LTE/PROCESS INDICATOR/384/2018-19

Technical Specifications:

S No	Particulars	Specifications/BNPM Requirement	Bidder offered specifications	Deviations (if any)
1	Material	Universal Input Process Indicator		
2	Type	Microprocessor / Microcontroller based		
3	Configuration/Programming	Through Front Facia Keys		
4	Input Type	Universal inputs (4-20 mA DC CURRENT, mV, RTD (Pt-100, Pt-1000) Thermocouple, 1-5V DC etc, (configurable)		
5	Transmitter Power Supply	24V DC @ 30 mA or Better		
6	Display	5-digit, 0.8"(20.3mm) Height, LED/TFT Display		
7	Decimal Point Position	Configurable		
8	Accuracy	+/- 1% of FSD		
9	Relay Output	2 SPDT Relay (2NO+2NC) required (Configurable High/Low Alarms) + Display LED's		
10	Relay Ratings	230 V AC, 5A (Resistive)		



Limited Tender Enquiry No: BNPM/LTE/PROCESS INDICATOR/384/2018-19

11	Enclosure Material	Metallic/PC/ABS		
12	Ingress Protection Class	IP65 for front facia or better		
13	Power Supply	10 – 30 V DC		
14	Dimensions	Front: 48mm(H) x 96mm(W) x 65mm /STD (D) Panel Cut Out: 45mm(H) x 92mm (W)		
15	Mounting Accessories	Required for Panel Mounting		
16	User Manual	01 set required		
17	Diagnostic Messages	Process overflow, Process underflow and Sensor break		
18	Ambient Temperature	0 - 55°C		
19	Relative Humidity	Up to 95% Non-condensing		
20	Make:	Multispan, Masibus, Phoenix Contacts, Yokogawa, M-Systems, ABB, Siemens		

Note:

1. The bidder has to quote technical parameters in the above format only, clearly indicating the deviations (if any).
2. All suggestions/recommendations should be accompanied by drawings/catalogues/manuals mandatorily.
3. Traceable Test Certificate and Warranty Certificate should be supplied.

(To be signed & stamped and submitted along with Price Bid).



Limited Tender Enquiry No: BNPM/LTE/PROCESS INDICATOR/384/2018-19

Price Bid Format :

S No	Description	Qty	UOM	Unit rate	Freight, P&F Charges	GST @ 18% (HSN - 8473)	Unit rate including GST & Freight, P&F Charges	Grand total inclusive of GST and Freight, P&F Charges (D.A.P, BNPM, Mysore)
1	Supply of Panel Mounted Universal Input Process Indicator as per technical specifications	5	Nos					
Total price inclusive of all tax, freight , P&F charges								

HSN Codes: (8473)

We hereby confirm that

1. We accept all terms & conditions mentioned in the enquiry.
2. Price quoted is inclusive of all taxes, P&F, freight etc. on D.A.P, BNPM, Mysore basis.

Signature of bidder:.....

Name of the Firm:.....

Seal of the firm:

GST No:

