

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED,
CIN: U21090KA2010PTC055475
CORPORATE OFFICE, MYSORE
Email: bhoodhar@bnpmindia.com
Tel: 0821-2401-174

**ENQUIRY No: BNPM/ENQ/ DIGITAL MOTOR CHECKER FOR TESTING OF
MOTOR/463/2017-18**

Start Date: 20.03.2018

END Date: 23.03.2018

1. Scope of work:

Supply of “**Digital Motor Checker for testing for motor**”.

2. Terms & Conditions:

S. No.	Particulars	Quantity
1.	Payment Terms	100% on receipt and acceptance of goods by the consignee at destination and on production of all required documents by the supplier. <u>NEFT/RTGS details shall be furnished along with invoice.</u>
2.	Price	Price should be inclusive of all taxes & duties.
3.	Freight	Shall be included in quoted price
4.	Packing & Forwarding	Shall be included in quoted price
5.	Delivery Terms	DAP, Bank Note Paper Mill India Private Limited, Mysore
6.	Warranty Period(Please specify)
7.	Warranty Certificate	Applicable/ Not Applicable
8.	Delivery Period(Please specify)
9.	Material to be delivered at	Engineering Stores Bank Note Paper Mill India Private Limited Note Mudran Nagar Mysore 570 003

Remarks: Quotation should send by mail to bhoodhar@bnpmindia.com.



3. Price Bid Format :

S. No.	Description	Qty. A	UOM B	Unit rate C	GST @.....% D	Total E=C+D	Grand Total F=E*A	
1	Digital Motor Checker for testing for motor Specification as per Annexure-1	1	NOS					
		Grand Total						
Grand Total In Words:								

We hereby confirm that

1. We accept all terms & conditions mentioned in the enquiry.
Price quoted is inclusive of all taxes, duties, P&F, freight etc. on DAP, BNPM, Mysore basis.

Signature of bidder:

Name of the Firm:

Seal of the firm:



ANNEXURE - I

Technical Specifications:

Insulation Resistance(IR): 0 to 200 M Ω at 500V DC \pm (2% + 1digit), 0.1 M Ω resolution
0 – 2000 M Ω at 1000 V DC \pm (2% + 1digit), 1 M Ω resolution

Inductance: 0 to 2000mH in 4 ranges & Rotor test

Range	(mH)	F.S.R	Resolution	Tolerane
1	2000		1mH	\pm 3
2	200		0.1mH	\pm 3
3	20		0.01mH	\pm 3
4	2		0.001mH	\pm 3

Low Resistance: 0 to 200 Ω in 4 ranges

Range	(OHMS)	F.S.R	Resolution	Tolerane
1	200		0.10 Ω	\pm 2
2	20		0.01 Ω	\pm 2
3	2		0.001 Ω	\pm 2
4	0.2(200m Ω)		0.10milli Ω	\pm 2

3 ½ digit LCD Display, Battery Low indication
Enclosure: Moulded in High impact ABS

Additional Accessories: 1.Spare Test Leads

A. *[Signature]*