



Bank Note Paper Mill India Private Limited
Registered & Corporate office: Paper Mill Compound,
Entry Gate 1, Note Mudran Nagar,
Mysore-570003
CIN: U21090KA2010PTC055475.

Standard Biding Document (SBD)

Not Transferable

e-Tender Document for –**Supply, installation, testing and supervision of erection & commissioning of LT panels**

e-Tender No. BNPM/TEN/LT PANEL/379/2017-18 dated 31.01.2018

The Tender Document contains 55 Pages

The Tender Document is sold to

M/s
Address

Details of Contact person in BNPM regarding this tender

Name: Alok Kumar

Designation: Deputy General Manager

Address Administrative office Building,
Entry Gate 1, Paper Mill Compound,
Note Mudran Nagar,
Mysore – 570003, Karnataka, India
Phone 0821-2401111
Email info@bnpmindia.com
Website: www.bnpmindia.com



CONTENTS – STANDARD BIDDING DOCUMENT

Section No	Specification no	Description
I.	BNPM/TEN/LT PANEL/379/2017-18	Notice Inviting Tender (NIT)
II.	GIT	General Instructions to Tenderers
III.	SIT	Special Instructions to Tenderers
IV.	GCC	General Conditions of Contract
V.	SCC	Special Conditions of Contract
VI.	LOR	List of Requirements
VII.	TS	Technical Specifications
VIII.	QCR	Quality Control Requirements
IX.	QC	Qualifying/ Eligibility Criteria
X.	TF	Tender Form/ Acceptance of Terms & Conditions
XI.	PS	Price Schedule
XII.	QUEST	Questionnaire
XIII.	BG-EMD	Bank Guarantee Form for EMD
XIV.	MAF	Manufacturer's Authorization Form
XV.	BG-PS	Bank Guarantee Form for Performance Security.
XVI.	CF	Contract Form – Not Applicable
XVII.	LOA	Letter of Authority for attending Bid Opening – Not Applicable
XVIII.	SA	Shipping Arrangements for Liner Cargoes – Not Applicable
XIX.	PBP	Proforma of Bills for Payments - Not Applicable
XX.	APQ	Application-Pre-Qualification
XXI.	ACW	Additional Conditions of Works Contract
XXII.	IP	Proforma for Integrity Pact - Not Applicable

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

Paper Mill Compound, Note Mudran Nagar

Mysore-570003

Tele: 0821-2401 180; Fax No: 0821-2581 154

Email: ssharma@bnpmindia.com , website: www.bnpmindia.com

(Name, address, telephone no., Fax, e-mail, website etc. of the Unit)

BNPM/TEN/LT PANEL/379/2017-18 dated 29.01.2018

1. Bidders satisfying the technical and commercial conditions specified in the bid and ready to supply the mentioned products in conformity with the Scope of Supply and Technical specification provided in NIT and terms and conditions stipulated herein may submit their commercial quotes as specified in the format of the document. **The closed quote should be submitted electronically only on the BNPM e-Tendering Portal www.tenderwizard.com/BNP within the time:**
2. Tenders are invited in two parts (Techno-commercial & Financial) from eligible and qualified tenderers for supply of following Goods:

S.No	Brief Description of Goods/ Services	Qty. with units	Earnest Money Deposit*
1	Supply, installation, testing and supervision of erection & commissioning of LT panels	As per Section VI - LOR	Rs. 30,000/- (Rupees thirty thousand only)

*The tenderers who are currently registered and, also, will continue to remain registered during the tender validity period with DGS&D or with National Small Industries Corporation, New Delhi /MSME are exempted from payment of earnest money. In case the tenderer falls in these categories, it should furnish certified copy of its valid registration details (with DGS&D or NSIC or MSME as the case may be).

Tender Number	BNPM/ TEN/ LT PANEL/379/2017-18 dated 29.01.2018
Type of Tender (Two Bid/PQB/EOI Etc.)	Two Bid
Details of Sales of tender Documents	E tender
Price of the tender Documents	Rs. 1,000/- + Taxes
Bid Submission Mode	Through e-tendering portal www.tenderwizard.com/BNP
Closing date and time for submission of bids along with supporting documents through e-tendering portal.	21.02.2018

3. Interested tenderers may obtain further information about this requirement from the above office selling the documents. They may also visit our website www.tenderwizard.com/BNP mentioned above for further details.
4. Non-refundable Tender fee is Rs. 1,000/- per set plus applicable taxes. The payment shall be made through Electronic mode only.

5. Aspiring Bidders/Contractors who have not registered in e-tendering should register through the website E - Tendering (www.tenderwizard.com/ BNP) for participating in the Online Tenders. The registration charges will be Rs. 1500/- plus applicable taxes (per year) which needs to be paid through electronic mode only.
6. For details, registration and e-payment, please visit e-tendering website www.tenderwizard.com/BNP or contact Mr. Nagesh 96861 15324.
7. The NIT Form with standard tender documents will be accessible in the e-Tendering website (viz www.tenderwizard.com/BNP).
8. Class III Digital Signature Certificate (DSC) is mandatory to participate in e-Tenders. Participating bidders/Contractors have to make sure that they have the valid DSC. If not, they can procure from any of the RAs approved by CCA.
9. Bidders/Contractors should upload and attach all the Scanned copies of technical documents / certificates in e-tendering website www.tenderwizard.com/BNP pertaining to their eligibility criteria mentioned in the NIT, failing which, the bid will not be considered.
10. For those tenderers whose technical bids do not satisfy the eligibility criteria, their financial Bids will not be opened.
11. The tender shall contain two bid systems each of whose contents shall be as follows.

Prequalification Bid & Techno-commercial Bid should consist of clearly visible scanned copy of:

- i) Bid forwarding letter.
- ii) Power of Attorney in favour of the person who has signed the bid on stamp paper (Rs.100/- non judicial stamp paper)
- iii) Documents to establish conformity with Bidder's Qualification / Eligibility criteria.
- iv) ESIC, PAN details, GST registration certificate, Schedule bar chart
- v) Earnest Money Deposit (To be paid through electronic mode only)
- vi) Deviations from GCC, SCC, SIT, GIT
- vii) Schedule of deviations to technical specifications separately
- viii) Technical details / documents specified in technical part
- ix) Blank copy (Without price) of Schedule of price duly signed & stamped on each page

The bidder should submit the "Prequalification Bid & Techno-Commercial bid" in e-tendering portal.

Financial Bid shall contain.

- i) Schedule of Prices duly filled in.

The bidder should submit the- "Financial Bid" in e-tendering portal.

NIT

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

SECTION: I

NOTICE INVITING TENDER

SHEET 3 OF 3

12. Tenderers shall ensure that their tenders, duly sealed and signed, complete in all respects as per instructions contained in the Tender Documents, should be uploaded in e-tendering portal (www.tenderwizard.com/BNP) only.

13. In the event of any of the above mentioned dates being declared as a holiday / closed day for the purchase organisation, the tenders will be sold / received / opened on the next working day at the appointed time.

14. The tender documents are not transferable.

Yours Faithfully,

(Alok Kumar)
Deputy General Manger



GIT	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SECTION: II
	GENERAL INSTRUCTIONS TO TENDERERS	SHEET 1 OF 1

Section II: General Instructions to Tenderers (GIT)

This section-II shall be downloaded from website: www.bnpmindia.com under the section "Corporate Actions" and signed & stamped and submitted along with the Techno-Commercial Bid –Part II as acceptance of terms and conditions.

(Offer without the copies of section-II shall liable to be rejected).



ISSUE
Rd

The following Special Instructions to Tenderers will apply for this purchase. These special instructions will modify/ substitute/ supplement the corresponding General Instructions to Tenderers (GIT) incorporated in Section II. The corresponding GIT clause numbers have also been indicated in the text below:

In case of any conflict between the provision in the GIT and that in the SIT, the provision contained in the SIT shall prevail.

SI No	GIT Clause no	Topic	SIT Provision
1	1,2,3,4,5,6, 7	PREAMBLE-Introduction, Language of Tender, Eligible Tenderers, Eligible Goods and Services (Origin of Goods), Tendering Expense, TENDER DOCUMENTS, Amendments to Tender Documents	No Change
2	8	Pre-bid Conference	Not applicable to this tender
3	9	Time Limit for receiving request for clarification of Tender Documents	No Change
4	10,11,12, 13,14,15	Documents Comprising the Tender, Tender Currencies, Tender Prices, Indian Agent, PVC Clause & Formula, Alternative tenders	No Change
5	16	Documents Establishing Tenderer's Eligibility and Qualifications	No Change
6	17	Documents establishing Good's Conformity to Tender document	No Change
7	18	Earnest Money Deposit (EMD) Note: Bidders claiming exemption of EMD should submit the DGS&D (or) NSIC registration certificate without fail along with their techno-commercial offer. EMD exemption for DGS&D (or) NSIC registered firm. Cost of tender to be submitted	No Change
8	19	Tender Validity (120 days in case of two-bid system after the date of tender opening prescribed in the tender document)	No Change
9	20	Signing and Sealing of Tender Note: The following SIT provision is made with respect the following clause 20.4. Number of Copies of Tenders to be submitted : Nil 20.9: E procurement: Only E Procurement permitted.	Only E Procurement
10	21,22,23	Submission of Tenders, Late Tender, Alteration and Withdrawal of Tender	No Change
11	24	Opening of tenders	No Change

SIT**BANK NOTE PAPER MILL INDIA PRIVATE LIMITED**

SECTION: III

SPECIAL INSTRUCTIONS TO TENDERERS

SHEET 2 OF 2

		Note: Please read the guidelines for filling up two part bid tender as mentioned in NIT above which is described in detail w.r.to clause 24.4	
12	25	Basic Principle	No Change
13	26,30,28, 29,30,31, 32,33,34	Preliminary Scrutiny of Tenders, Minor Infirmary / Irregularity / Non-Conformity, Discrepancy in Prices, Discrepancy between original and copies of Tender, Clarification of Bids, Qualification / Eligibility Criteria, Conversion of tender currencies to Indian Rupees, Schedule-wise Evaluation, Comparison on CIF Destination Basis.	No Change
14	35 to 49	Additional Factors and Parameters for Evaluation and Ranking of Responsive Tenders, Tenderer's capability to perform the contract, Tenderer's capability to perform the contract, Cartel Formation / Pool Rates, Negotiations, Contacting BNPMIPL, AWARD OF CONTRACT, Award Criteria, Variation of Quantities at the Time of Award, Parallel Contracts, Serious Misdemeanors, Notification of Award, Issue of Contract, Non-receipt of Performance Security and Contract by BNPMIPL, Return of EMD, Publication of Tender Result.	No Change
15	50 to 55	Rate Contract Tenders, PQB Tenders, Tenders involving Purchaser's and Pre-Production Samples, EOI Tenders, enders for Disposal of Scrap, Development / Indigenization Tenders	Not applicable to this tender



GCC	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SECTION: IV
	GENERAL CONDITIONS OF CONTRACT	SHEET 1 OF 41

Section IV: General Conditions of Contract (GCC)

This section-IV shall be downloaded from website: www.bnpmindia.com under the section "Corporate Actions" and signed & stamped and submitted along with the Techno-Commercial Bid –Part IV as acceptance of terms and conditions. ***(Offer without the copies of section-IV shall liable to be rejected)***



The following Special Conditions of Contract (SCC) will apply for this purchase. The corresponding clauses of General Conditions of Contract (GCC) relating to the SCC stipulations have also been incorporated below. These Special Conditions will modify / substitute / supplement the corresponding (GCC) clauses.

Whenever there is any conflict between the provision in the GGC and that in the SCC, the provision contained in the SCC shall prevail.

SI No	GCC Clause No	Topic	SCC Provision
1	1 to 5	Definitions; Interpretation and Abbreviations, Application, Use of contract documents and information, Patent Rights, Country of Origin	No Change
2	6	Performance Security	No Change
3	7 to 15	Technical Specifications and Standards, Packing and Marking, Inspection and Quality Control, Terms of Delivery, Transportation of Goods, Insurance, Spare parts, Distribution of Dispatch Documents for Clearance/ Receipt of Goods	No Change
4	16	Warranty	No change
5	17& 18	Assignment, Sub Contracts	No Change
6	19	Modification of contract	No Change
7	20 & 21	Prices, Taxes and Duties	GST as applicable shall be quoted
8	22	Terms and Mode of Payment	a) 90% on receipt and acceptance of material by the consignee at destination and on production of all required documents by the supplier. b) 10% after successful erection, commissioning & performance test of LT panels (Power distribution boards).
9	23 to 32	Delay in the supplier's performance, Liquidated damages, Custody and Return of BNPM's Materials/ Equipment/ Documents loaned to Contractor, Termination for default, Termination for insolvency, Force Majeure, Termination for convenience, Governing	No Change



SCC**BANK NOTE PAPER MILL INDIA PRIVATE LIMITED**

SECTION: V

SPECIAL CONDITIONS OF CONTRACT

SHEET 2 OF 2

		language, Notices, Code of Ethics	
10	33	Resolution of disputes	Arbitration proceedings will be held at Mysuru and venue of arbitration will be Mysuru
11	34-35	Applicable Law, Secrecy,	No Change
12	36	Disposal / Sale of Scrap by Tender	NOT APPLICABLE TO THIS TENDER



1. Scope of work

- a. Supply, testing and supervision of erection & commissioning of following panels:

Sl.No	Description of Items and Work	Quantity
1	Minipress MPDB (Main power distribution board)	1 No.
2	Minipress MLDB (Main lighting distribution board)	1 No.
3	PM1 – Sub- EPDB (Emergency power distribution board)	1 No.

This specification covers specific requirements of design, preparation of detailed drawings, manufacture, testing and inspection at Vendor's/Sub-Vendor's works, packing, forwarding, transportation, transit insurance and delivery at site, unloading, supervision for erection and commissioning of Power distribution Boards as per enclosed data sheets.

2. CODES AND STANDARDS

- 2.1 The design, manufacture, performance testing and inspection of equipment shall comply with all currently applicable statutory regulations and safety codes in the locality, where the equipment will be installed, Nothing in this specification shall be construed to relieve the VENDOR of this responsibility.
- 2.2 Unless otherwise specified, the equipment shall conform to the latest applicable IS, BS or IEC Standards.

3. SPECIFIC REQUIREMENTS FOR POWER DISTRIBUTION BOARDS(PDB)

(REFER ATTACHED SLD DRAWING OF MPDB, MLDB and PM1- Sub EPDB)

3.1 ACB Incomer

- 3.1.1 415V, 4 pole, 50/65 kA for 1 sec, Electrical drawout Air Circuit Breaker with microprocessor based overload, short-circuit and earth fault releases with time and current adjustable and complete with anti-pumping feature, auxiliary contacts, closing coil, tripping coil, motorised

spring charging mechanism with manual charging facility, and 6NO + 6NC (min.) auxiliary contacts.

- 3.1.2 For ACB's $I_{cu} = I_{cs} = I_{cw}$ shall be 100%
- 3.1.3 Closing, tripping coils and indication shall be suitable for 110V DC /230V AC supply. Spring charging motor, space heater supply and panel illumination lamp shall be suitable for 240V AC supply. AC/DC voltages shall be as per SLDs.
- 3.1.4 The front panel of the circuit breaker truck shall have :
- Mechanical push buttons for breaker close/open.
 - Mechanical indications for spring charge/discharge.
 - Mechanical indication for breaker ON/OFF
 - Breaker Position indication.
 - Operation counter.
- 3.1.5 T-N-C breaker control switch, spring return to neutral position with lost motion contacts.
- 3.1.6 Red, Green, Amber, White, Blue and Green clustered LED indicating lamps for breaker ON, OFF, Trip, Trip circuit healthy, Spring charged and breaker in service and breaker in test position respectively suitable for 110V DC/230V AC supply. AC/DC voltages shall be as per SLDs.
- 3.1.7 Emergency trip push buttons with hinged acrylic cover.
- 3.1.8 Digital multifunction meter suitable for 415V voltage and 1A current input, displaying all electrical parameters like current, voltage, frequency, active, reactive and apparent power, energy and P.F. along with test terminal block.
- 3.1.9 Analogue Ammeter with selector switch suitable for 1 A CT secondary.
- 3.1.10 Analogue Voltmeter with selector switch suitable for connecting to 110 V AC supply.
- 3.1.11 Cast resin CTs for metering & protection and as per attached SLD. STC shall be as per SLD.

3.2 ACB Outgoing Feeder

- 3.2.1 415V, 4 pole, 50/65 kA for 1 sec, Electrical drawout Air Circuit Breaker with microprocessor based overload, short-circuit and earth fault releases with time and current adjustable and complete with anti-pumping feature, auxiliary contacts, closing coil, tripping coil, motorised spring charging mechanism with manual charging facility, and 6NO + 6NC (min.) auxiliary contacts.

- 3.2.2 For ACB's $I_{cu} = I_{cs} = I_{cw}$ shall be 100%
- 3.2.3 Closing, tripping coils and indication shall be suitable for 110V DC /230V AC supply. Spring charging motor, space heater supply and panel illumination lamp shall be suitable for 240V AC supply. AC/DC voltages shall be as per SLDs.
- 3.2.4 The front panel of the circuit breaker truck shall have :
- Mechanical push buttons for breaker close/open.
 - Mechanical indications for spring charge/discharge.
 - Mechanical indication for breaker ON/OFF
 - Breaker Position indication.
 - Operation counter.
- 3.2.5 T-N-C breaker control switch, spring return to neutral position with lost motion contacts.
- 3.2.6 Red, Green, Amber, White, Blue and Green clustered LED indicating lamps for breaker ON, OFF, Trip, Trip circuit healthy, Spring charged and breaker in service and breaker in test position respectively suitable for 110V DC/230V AC supply. AC/DC voltages shall be as per SLDs.
- 3.2.7 Emergency trip push buttons with hinged acrylic cover.
- 3.2.8 Digital multifunction meter suitable for 415V voltage and 1A current input, displaying all electrical parameters like current, voltage, frequency, active, reactive and apparent power, energy and P.F. along with test terminal block.
- 3.2.9 Cast resin CTs for metering & protection and as per attached SLD. STC shall be as per SLD.

3.3 MCCB Incomer Feeder

- 3.3.1 It shall be suitable for 415 V, --A, 50 kA/ 65kA/35kA, 4 Pole MCCB, drawout type microprocessor based over load short circuit and earth fault releases with time and current adjustment with shunt trip coil or MCCB shall have 1NO+1NC auxiliary contacts for ON and OFF indication and 1NO+1NC alarm contacts for trip indication.
- 3.3.2 MCCB shall be provided with door operating handle with pad lock arrangement and door interlock facility with door interlock defeat facility.
- 3.3.3 3 Nos. 1 phase, ---/5A, 7.5 VA, CL-1.0, 1 core cast resin CTs for metering with CT ratio as indicated in SLD.
- 3.3.4 Digital multifunction meter suitable for 415V voltage and 5A/1A current

input, displaying all electrical parameters like current, voltage, frequency, active, reactive and apparent power and energy, P.F. etc. along with test terminal block.

3.3.5 ON (Red), OFF (Green) & Trip (Amber) indicating lamps suitable for 240V AC supply shall be provided.

3.3.6 Emergency trip push button.

3.4 Outgoing MCCB Feeder

3.4.1 It shall be suitable for 415 V, --A, 50 kA/ 65kA/35kA, 4 Pole MCCB, drawout type microprocessor based over load short circuit and earth fault releases with time and current adjustment with shunt trip coil or MCCB shall have 1NO+1NC auxiliary contacts for ON and OFF indication and 1NO+1NC alarm contacts for trip indication.

3.4.2 MCCB shall be provided with door operating handle with pad lock arrangement and door interlock facility with door interlock defeat facility.

3.4.3 ON (Red), OFF (Green) & Trip (Amber) indicating lamps suitable for 240V AC supply shall be provided.

3.5 Changeover Panel

3.5.1 It will consists of two breakers of rating 800A, 415V, 4 pole, 50 kA for 1 sec, Electrical draw out Air Circuit Breaker with microprocessor based overload, short-circuit and earth fault releases with time and current adjustable and complete with anti-pumping feature. auxiliary contacts , closing coil, tripping coil, motorized spring charging mechanism with manual charging facility, castle key and 6NO + 6NC (min.) auxiliary contacts. It shall be communicable on Modbus communication protocol (RS 485). It shall communicate Breaker Status, Trip history, and maintenance parameters Status to purchaser DCS system. Short circuit capacity (STC) shall be as per SLDs. Trip unit of the Breaker shall have thermal memory, Display and rotary dials to adjust the various release as indicated above.

3.5.2 It will have electrical/ Mechanical interlock (Castle key) with two breakers, at a time only one breaker will be in operation.

3.5.3 For ACB's leu= lcs= lew shall be 100%

3.5.4 Closing, tripping coils and indication shall be suitable for 230V AC/DC supply & spring charging motor, space heater and panel illumination

lamp supply shall be suitable for 240V AC supply.

- 3.5.5 The front panel of the circuit breaker truck shall have :
- Mechanical push buttons for breaker close/open.
 - Mechanical indications for spring charge/discharge.
 - Mechanical indication for breaker ON/OFF
 - Breaker Position indication.
 - Operation counter.
- 3.5.6 T-N-C breaker control switch, spring return to neutral position with lost motion contacts.
- 3.5.7 Red, Green, Amber, White, Blue and Green clustered LED indicating lamps for breaker ON, OFF, Trip, Trip circuit healthy, Spring charged and breaker in service and breaker in test position respectively suitable for 230V AC/ DC supply.

4. GENERAL REQUIREMENTS :

- 4.1 Power distribution boards (PDB/MPDB) shall be 415V, 3 Phase, Neutral, 50 Hz, 50 kA/35 kA for 1 sec. STC shall be as per SLDs.
- 4.2 It shall be single/ double front, free standing, vertical, fixed type except ACB feeder type as specified, cubical type having hinged access doors with locking type latches and extensible at both the ends. Single/double front shall be as per SLD.
- 4.3 ACB Shall be Equivalent to Siemens - Sentron WL, Schneider- Materpac, L& T U Power Omega and ABB Emax with equivalent releases as asked in the specification. Similarly MCCB shall also be of equivalent category & make.
- 4.4 Panel supporting structural frame of suitable size shall be in panel manufacture's scope.
- 4.5 PDB shall be suitable for Top & Bottom cable entry. It shall be suitable for required no of cable terminations as per the voltage drop and load current which will be given to successful bidder.
- 4.6 Degree of protection of panels shall be IP54/IP42 for Ventilated Boards.
- 4.7 Minimum thickness of sheet steel (cold rolled) shall be as follows:
- Base frame and top frame - 2 mm or 2.5 mm depending upon requirement.
 - Side and top Cover plates - 2 mm
 - Busbar and cable chamber covers / doors - 2mm
 - Circuit breaker compartment door-2 mm

- e) Instrument front plate – 2 mm or 2.5 mm depending upon requirement.
 f) Equipment plate – 2 mm
 g) Gland plate – 3 mm
- 4.8 All panels shall have uniform panel height.
- 4.9 The busbars shall be either Aluminum/Copper as per SLD. STC shall be as per SLD.
- 4.10 The main busbars (horizontal as well as vertical) shall have uniform current ratings throughout their length.
- 4.11 Busbars shall be provided with color coded heat shrunk PVC sleeves.
- 4.12 FRP shrouds shall be provided at joints and tap offs.
- 4.13 Calculations for busbar sizing shall be furnished by vendor.
- 4.14 Support insulators shall be made of non-hygroscopic, non-inflammable materials.
- 4.15 Nylon FRP or Bakelite insulators shall not be used in any panel.
- 4.16 All panels shall be provided with lifting hooks. Lifting hooks/eyes for equipment shall be removable type. Lifting hooks shall be provided on blind holes (The removal of lifting hooks shall not result in opening in the equipment enclosure).
- 4.17 Operating height shall be restricted between 250 mm to 1800mm from finished floor level.
- 4.18 Panels shall be treated with 7 Tank pre-treatment processes.
- 4.19 Panels shall be epoxy powder coated painting having color shade interior and exterior pebble grey (shade RAL 7032 as per DIN standard). Pre-treatment shall be given.
- 4.20 Panel enclosures shall be provided with arrangement for clamping & proper dressing of cables/wires.
- 4.21 All push buttons shall be fitted with two (2) NO and two (2) NC contacts, rated for 10 A at 240V AC.
- 4.22 All indicating lamps shall be Cluster LED type.
- 4.23 All metallic enclosures/panels shall be with detachable/removable undrilled gland plates.
- 4.24 Cable alley shall be provided with removable hinged door (Front and back).
- 4.25 Cable supporting arrangement (if required) shall be provided in Cable chamber / Cable alley.
- 4.26 Rubber grommets shall be used for all wire entries to make panel dust and vermin proof.

- 4.27 Special attention shall be paid to door alignment. Observation of any improper alignment (esp. of doors) shall lead to summary rejection of the panel/switchboard, whether at shop floor or at site.
- 4.28 All hinged doors shall open min. 105 Deg.
- 4.29 All doors shall be with concealed type hinges and captive screws.
- 4.30 Side covers shall be with removable panels.
- 4.31 Drawing pocket shall be provided for each Panel. Drawing set in the panel shall be laminated.
- 4.32 Danger caution boards shall be provided on front as well as rear side on busbar chamber for each shipping section.
- 4.33 Panels shall be provided with AL. Earthing Bus.
- 4.34 Door/cover earthing shall be done with flexible tinned copper braid.
- 4.35 Rear doors of panels requiring rear access shall be provided with removable hinged doors. These doors shall be also be earthed even on these doors no equipment is mounted.
- 4.36 MCBs as required shall be provided.
- 4.37 Internal wiring shall be done with 2.5 sqmm copper conductor HFFR wires for CT circuits and 1.5 SQMM for all the remaining circuits.. Wiring shall be neatly done.
- 4.38 CT wires shall have RYB colored sleeves at termination.
- 4.39 All the feeders shall be provided with Test Terminal Block.
- 4.40 Red T- type ferrules shall be provided for tripping circuit.
- 4.41 All spare potential free contacts shall be wired upto terminal block.
- 4.42 Terminal block with 20% spare terminals.
- 4.43 Terminals, busbar arrangements and sizes and terminal boxes shall be suitable for termination of Copper / Aluminum cables as indicated.
- 4.44 PVC insulation tapes shall not be acceptable for any terminations. At all terminations only color coded PVC sleeves shall be acceptable.
- 4.45 All labels shall be white acrylic with black engraving.
- 4.46 All components for all electrical items (esp. in all panels) shall be properly labeled.
- 4.47 Internal components shall be provided with self-adhesive stickers.
- 4.48 External Name plate shall be of 3 ply with white letters on black background or as per OEM engineering practice.
- 4.49 Terminal block shall be suitable for minimum 2.5 sq. mm wire & rated for

minimum 20A.

4.50 Drop link terminals equivalent to CATD shall be provided for CT.

4.51 All terminal blocks shall be clip-on-stud or stud type or motor type only. Screw type/ terminals pass-through/Clip-on terminals shall not be acceptable.

4.52 In each cable alley and LT compartment of ACB panel, following shall be provided.

(a) Panel Space heater of appropriate wattage along with thermostat and MCB.

(b) Industrial type 240V AC, 5A Socket.

(c) Panel Illumination lamp along with MCB. Panel illumination shall be with enclosures 13W CFL bulkhead luminary shall be used.

(d) Controls, Interlocking for different systems shall be as per respective system details.

5. TESTS

5.1 Power distribution Boards (PDBs) shall be offered by bidder for inspection before dispatch to site. Inspection shall be carried out as per relevant IS/BS/IEC standards.

5.2 All meters and other reference devices used for testing shall have valid calibration from reputed national laboratories/institutes

5.3 Typical type test certificates of similar ratings shall be made available to purchaser.

5.4 These test reports and manufacturer's type test reports shall be submitted to the BNPM before dispatch of the equipment.

6. DRAWINGS AND DATA

6.1 As part of the proposal, the BIDDER shall furnish the following drawings and data for scrutiny along with offer.

(a) General arrangement drawings, make and type of panels.

(b) Major Bill of materials for major equipment listing equipment designation, make, type, rating etc. panel wise of the various accessories & components used for the above equipment.

(c) Typical type test certificates of similar ratings.

(d) Bidder shall furnish technical particulars and detailed technical brochures on the equipment offered.

(e) Filled up data sheet for each panel.

6.2 Bidder shall furnish the following drawings after award of contract.

- (a) General Arrangement drawing showing dimensioned views, cable entry location and mounting details.
- (b) Panel inter-wiring details, terminal block details, control & indication circuit wiring details etc.
- (c) Bill of material for all equipment listing equipment designation, make, type, rating etc. panel wise of the various accessories & components used for the above equipment.
- (d) Typical type test certificates of similar ratings.
- (e) Filled up data sheet for each panel.

7. SPARES

7.1 Bidder shall indicate the recommended spares for two years operation after commissioning.

8. APPROVED MAKES

- 8.1 Air Circuit Breaker - Siemens /Schneider/L&T/ABB
- 8.2 Moulded Case Circuit Breaker - Siemens /L&T/Schneider/ABB
- 8.3 Contactors, Thermal overload Relays – Siemens /L&T/Schneider/ABB
- 8.4 Changeover switch- Havells (euroload) / C & S / HPL Socomech
- 8.5 Current Transformer - Kappa/ Pragati / Indcoil / Precise
- 8.6 Digital Multifunction Meter – Schneider / Satec/Siemens
- 8.7 Analogue Ammeter and Voltmeter – AE / Rishabh / Conzerve
- 8.8 Breaker Control switch - Alstom / Kaycee
- 8.9 Selector Switches - Kaycee / Siemens / Salzer
- 8.10 LED Indicating lamps - Teknic / Siemens /Schneider
- 8.11 Push Buttons – Siemens/Teknic/Schneider
- 8.12 MCB – Siemens / Schneider/Hager/Legrand
- 8.13 Terminal Block – Connectwell / Elmex / Wago
- 8.14 Switch-socket – Anchor/ Reputed
- 8.15 Space Heater – Girish/ reputed

Any other make subject to prior approval of purchaser.

MPDB/MLDB / PM1 Sub-EPDB DATA SHEET

(To be filled by Bidder)

1.0	SPECIFIC PARTICULARS	UOM	To be filled by bidder
1.1	Switchgear designations		
1.2	Single front	SF	
1.3	Applicable Standard		
1.4	Fully drawout/semi drawout/Fixed	FD/SD/F	
1.5	Total dimensions of each complete switchgear L x W x D	mm	
1.6	Width of each vertical Section with cable alley Width of cable alley only	mm mm mm	
1.7	Minimum clear space required		
	a) In front	mm	
	b) Back	mm	
1.8	Max. cubicle weight with components	kg	
2.0	GENERAL PARTICULARS		
2.1	Sheet steel		
	a) Cold rolled/Hot rolled		
	b) Thickness :	mm	
	i) Frames		
	ii) Door		
	iii) Rear cover		
	iv) Side and top covers		
	v) Panel partitions		
2.2	Degree of protections provided by the enclosure (As per IS : 13847)		
2.3	Earth busbar size	Sq.mm	GI/AL/CU
3.0	BUSBAR		
	a) Material of busbars		AL/CU
	b) Section	Sq.mm	PH : N:
	c) Continuous current rating under site conditions	A	
	d) Whether busbars have been insulated	Yes/No	
	e) Type of insulation		
	f) Temperature rise over the reference ambient when carrying rated current	°C	
	g) Material of busbar supports		

	h) Clearance in air :		
	1) Between phases	mm	
	2) Between phases earth	mm	
	i) Short time rating (One Sec.)	kA	
	j) Momentary rating (peak)	kA	
4.0	AIR CIRCUIT BREAKERS		
4.1	Maker's name		
4.2	Maker's type designation		
4.3	Applicable standards		
4.4	Type of releases and communication protocol		
4.5	Rated voltage	V	
4.6	Rated operating duty		
4.7	Rated current	A	
4.8	Derating factor for operation under site conditions		
4.9	Rated symmetrical breaking current at rated voltage. (Indicate power factor)	kA P.F.	
4.10	Rated peak making current	kA	
4.11	Rated short time withstand rating (for 1 sec)		
4.12	Operating mechanism type		
4.13	Limits of voltage for satisfactory operation of the following devices as a % of normal voltage		
	i) Operating mechanism	%	
	ii) Closing at normal voltage	%	
	iii) Closing coil	%	
	iv) Trip coil	%	
4.14	Power required for closing at normal voltage		
4.15	Power required for tripping at normal voltage		
4.16	Spring charging motor details :		
	i) Rating		
	ii) Rated voltage		
	iii) Spring charging		
4.17	Have electrical and mechanical anti-pumping features been provided		

5.0	Module case circuit breakers (MCCBs)		
5.1	Maker's name		
5.2	Maker's type designation		
5.3	Applicable standards		
5.4	Type of releases and communication protocol		
6.0	FUSES		
6.1	Make		
6.2	Type		
6.3	Applicable standards		
7.0	CONTACTORS		
7.1	Make		
7.2	Rated duty		
7.3	Rated Utilisation Category		
7.4	Applicable standards		
8.0	CURRENT TRANSFORMERS		
8.1	Make		
8.2	Type		
8.3	Applicable standards		
8.4	All other parameters of CT as per enclosed SLD and section-C	YES/NO	
9.0	CONTROL TRANSFORMERS		
9.1	Make		
9.2	Type		
9.3	Applicable standards		
9.4	Ratio		
9.5	Class of insulation		
9.6	Rated output	VA	
10.0	CONTROL/SELECTOR SWITCH		
10.1	Make		
10.2	Type designation		
11.0	VOLTMETER		
11.1	Make		
11.2	Type		
11.3	All other parameters of Voltmeter as per enclosed SLD and section-C		
12.0	AMMETER		
12.1	Make		
12.2	Type		
12.3	All other parameters of Ammeter as per enclosed SLD and section-C		



13.0	MULTIFUNCTION METERS		
13.1	Incomers		
13.1.1	Make		
13.1.2	Type		
13.1.3	All other parameters of MFM as per enclosed SLDs and section-C		
13.2	Outgoing feeders		
13.2.1	Make		
13.2.2	Type		
13.2.3	All other parameters of MFM as per enclosed SLDs and section-C		
14.0	INDICATING LAMPS		
14.1	Make		
14.2	Type		
15.0	PUSH BUTTONS		
15.1	Make		
15.2	Type designation		
16.0	SPACE HEATER		
16.1	Make		
16.2	Type		
16.3	Rated voltage	V	
16.4	Heater output for each vertical panel	W	
16.5	Thermostat at setting °C		
17.0	WIRING AND TERMINAL BLOCKS		
17.1	Voltage grade		
17.2	Insulation		
17.3	Minimum size of conductor for :		
	i) Power wiring	Sq.mm	
	ii) Control wiring	Sq.mm	
17.4	Type of terminal blocks :		
	i) For withdrawable Type		
	ii) For Fixed type		
17.5	Minimum current rating of terminal blocks	A	
17.6	Whether terminals for CT's have been provided with short circuiting facilities	YES/NO	

QCR	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SECTION: IX
	QUALITY CONTROL REQUIREMENTS	Sheet 1 of 1

Quality control requirements must be in accordance with Technical Specification mentioned in this tender document.



The pre-qualification criteria for the same are given as under:

Individual/ firm/ company/ corporate other than limited company/ manufacturer/ authorised distributor/representative intending to bid should be bonafide, experienced, technically competent, resourceful and financially sound to carry out the assigned order.

The bidder should be:-

- a) Registered under GST
- b) Having valid permanent Income Tax A/c No. as allotted by the Income Tax Authority of Government of India.
- c) Not blacklisted/ debarred by BNPM/ Bharatiya Reserve Bank Note Mudran (P) Limited (BRBNMPL) / Security Printing & Minting Corporation of India Limited (SPMCIL) or any Govt. Departments and
- d) **The detailed qualifying criteria are furnished below:**

Experience & Past Performance	The Bidder should have supplied at least one LV Switchgear panel (415 V / 3 phase) during the last 5 (five) years ending 31.12.2017.
Financial Standing	Average annual turnover of the bidder firm during last three years period ending 31-03-2017 should be more than Rs.4,50,000/-(Rupees four lakh fifty thousand only)
	Bidder Firms should not have suffered any financial loss for more than one year during the last three years period ending 31.03.2017.
	Net worth of the firm should not be in negative on 31.03.2017 and should have not eroded by more than 30% in the last three years period ending 31.03.2017.

Note: In case of non-availability of audited balance sheet for the financial year 2016-17. A provisional balance sheet and Profit / (loss) statement for the financial year 2016-17 duly signed by competent authority shall be submitted.

(Bidder shall qualify all the i.e. technical, financial and other pre-qualification criteria)

Note -1:

All experience, past performance and capacity/ capability related/ data should be certified by the authorised signatory of the bidder firm. The credentials regarding experience and past performance to the extent required as per eligibility criteria submitted by bidder may be verified from the parties for whom work has been done.

Scanned Documents to be uploaded in support of Pre-qualification Criteria

The following documents should be submitted by the firm to prove the pre-qualification criteria.

- a) Company's Profile including details along with copy of following documents:
 - a) Certificate of Incorporation/ Registration
 - b) Constitution of business, in case of business in individual name

- c) Partnership deed , in case of partnership
 - d) Memorandum of Association and Articles of Association, in case of Limited company
 - e) Memorandum of Association by corporate other than Limited company
- b) In support of technical standing copy of purchase order/work order/agreement and/ or work completion certificate issued by competent authority of the customer duly certified by authorised signatory.
- c) In support of financial standing copies of audited balance sheets and Profit & Loss account should be certified by authorised signatory. In case of unaudited balance sheet, same should be certified by certified accountant's e.g. Chartered Accounts (CA) in India and Certified Public Accountant/ Chartered Accountants of other countries.
- d) Declaration that the firm has not been blacklisted/ debarred by BNPMIPL/ BRBNMPL /SPMCIL or any Govt. Departments duly signed by authorised signatory. (Annexure I)
- e) Declaration towards acceptance to terms & conditions of tender (Annexure II)
- f) Compliance Format (Annexure III)
- g) If bidder is Licensed Partner of OEM, then an authorisation from OEM is to be enclosed as per Manufacturer's Authorisation Format (Section XIV)
- h) Copies of PAN and GST Certificates etc. to be submitted along with the bid.
- i) Format for the annexures indicated in the preceding paragraphs are available in section XX which the bidder may refer to.
- j) Any other relevant document the firm wishes to submit
- k) Details of Service Centre in Bangalore/Mysuru.

Bidder to furnish stipulated documents in support of qualifying criteria. Non-submission or incomplete submission of documents may lead to rejection of offer.

TF

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

SECTION: X

(ACCEPTANCE OF TERMS & CONDITIONS)

SHEET 1 OF 1

To

Date _____

Bank Note Paper Mill India Private Limited
Administrative Building, Entry Gate 1,
Paper Mill Compound,
Note Mudran Nagar,
Mysore - 570003

Ref: Your Tender document No.....dated.....

We, the undersigned have examined the above mentioned tender enquiry document, including amendment No. -----, dated ----- (if any), the receipt of which is hereby confirmed. We now offer to supply and deliver..... (description of goods and services) in conformity with your above referred document for the sum as shown in the price schedule(s), attached herewith and made part of this tender.

If our tender is accepted, we undertake to supply the goods and perform the services as mentioned above, in accordance with the delivery schedule specified in the List of Requirements.

We further confirm that, if our tender is accepted, we shall provide you with a performance security of required amount in an acceptable form in terms of GCC clause 6, read with modification, if any, in Section V- "Special Conditions of Contract", for due performance of the contract.

We agree to keep our tender valid for acceptance for a period up to -----, as required in the GIT clause 19, read with modification, if any in Section-III -"Special Instructions to Tenderers" or for subsequently extended period, if any, agreed to by us. We also accordingly confirm to abide by this tender up to the aforesaid period and this tender may be accepted any time before the expiry of the aforesaid period. We further confirm that, until a formal contract is executed, this tender read with your written acceptance thereof within the aforesaid period shall constitute a binding contract between us.

We further understand that you are not bound to accept the lowest or any tender you may receive against your above-referred tender enquiry.

(Signature with date)

(Name and designation)

Duly authorized to sign tender for and on behalf of

Bidder shall use this covering letter while submitting the offer.



SP**BANK NOTE PAPER MILL INDIA PRIVATE LIMITED****SCHEDULE OF PRICE**

SECTION XI

SHEET 1 OF 1

Prices are to be quoted in the price bid format given in the e-tender website (www.tenderwizard.com/BNP)

S. No.	Description	Unit	Quantity	HSN code	Price for Supply (in INR)	Price for testing and supervision of erection & commissioning (in INR)
1	Supply, installation, testing & supervision of erection & commissioning of Minipress MPDB (Main power distribution board)	Nos.	1			
2	Supply, installation, testing & supervision of erection & commissioning of Minpress MLDB (Main lighting distribution board)	Nos.	1			
3	Supply, installation, testing & supervision of erection & commissioning of PM1 – Sub- EPDB (Emergency power distribution board)	Nos.	1			
Freight and P&F charges						
Total price for Supply, testing and supervision of erection & commissioning of LT panels including freight and P&F charges						
GST amount						
Total price for Supply, testing and supervision of erection & commissioning of LT panels including GST, freight and P&F charges (DAP, BNPM, Mysore)						

QUEST	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SECTION: XII
	QUESTIONNAIRE	SHEET 1 OF 1

The tenderer should furnish specific answers to all the questions/ issues mentioned below. In case a question/ issue does not apply to a tenderer, the same should be answered with the remark "not applicable".

Wherever necessary and applicable, the tenderer shall enclose certified copy as documentary proof/ evidence to substantiate the corresponding statement.

In case a tenderer furnishes a wrong or evasive answer against any of the under mentioned question// issues, its tender will be liable to be ignored.

1. Brief description of goods and services offered:
2. Offer is valid for acceptance up to
3. Your permanent income tax A/c no. as allotted by the Income Tax Authority of Government of India
(Please attach certified copy of your latest/ current Income Tax clearance certificate issued by the above authority)
4. Status:
 - a) Are you currently registered with the Directorate General of Supplies & Disposals (DGS&D), New Delhi, and/ or the present BNPMIPL and/ or the Directorate of Industries of the concerned State Government for the goods quoted? If so, indicate the date upto which you are registered and whether there is any monetary limit imposed on your registration.
 - b) Are you currently registered under the Indian Companies Act, 1956 or any other similar Act?
(Please attach certified copy (s) of your registration status etc. in case your answer (s) to above queries is in affirmative.
5. Please indicate name & full address of our Banker(s)
6. Please state whether business dealings with you currently stand suspended/ banned by any Ministry/ Dept of Government of India or by any State Govt.

.....

(Signature with date)

(Full name, Designation & address of the person duly authorised sign on behalf of the tenderer)

For and on behalf of

.....

(Name, address and stamp of the tendering firm)

ISSUE R0



**BG-
EMD**

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

SECTION: XIII

BANK GUARANTEE FORM FOR EMD

SHEET 1 OF 1

NOT APPLICABLE TO THIS TENDER DOCUMENT



MAF

TATA CONSULTING ENGINEERS LIMITED

SECTION: XIV

MANUFACTURER'S AUTHORIZATION FORM

SHEET 1 OF 1

To

Bank Note Paper Mill India Private Limited
Administrative Building, Entry Gate 1,
Paper Mill Compound, Note Mudran Nagar,
Mysore – 570003

Dear Sirs,

Ref. Your Tender document No.....dated

We,, who are proven and reputable manufacturers of (name and description of the goods offered in the tender) having factories at.....hereby authorise Messrs (name and address of the agent) to submit a tender, process the same further and enter into a contract with you against your requirement as contained in the above referred tender enquiry documents for the above goods manufactured by us.

We further confirm that no supplier or firm or individual other than Messrs. (name and address of the above agent) is authorized to submit a tender, process the same further and enter into a contract with you against your requirement as contained in the above referred tender enquiry documents for the above goods manufactured by us.

We also hereby extend our full warranty, as applicable as per clause 16 of the General Conditions of Contract read with modification, if any, in the Special Conditions of Contract for the goods and services offered for supply by the above firm against this tender document.

Yours faithfully,

[Signature with date, name and designation)

For and on behalf of Messrs

.....

[Name & address of the manufacturers]

Note: This letter of authorisation should be on the letter head of the manufacturing firm and should be signed by a person competent and having the power of attorney to legally bind the manufacturer.



BG-PS

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

SECTION: XV

BANK GUARANTEE FORM FOR PERFORMANCE SECURITY

SHEET 1 OF 1

..... (Insert: Bank's Name, and Address of Issuing Branch or Office)

Beneficiary:

Bank Note Paper Mill India Private Limited
Administrative Building, Entry Gate 1,
Paper Mill Compound, Note Mudran Nagar,
Mysore - 570003

Date:.....

Performance Guarantee No.:

WHEREAS.....(name and address of the supplier) (hereinafter called "the supplier") has undertaken, in pursuance of LOI (Letter of Intent) no..... dated to supply (description of goods and services) (herein after called "the contract").

AND WHEREAS it has been stipulated by you in the said LOI that the supplier shall furnish you with a bank guarantee by a scheduled commercial bank recognized by you for the sum specified therein as security for compliance with its obligations in accordance with the LOI;

AND WHEREAS we have agreed to give the supplier such a bank guarantee;

NOW THEREFORE we hereby affirm that we are guarantors and responsible to you, on behalf of the supplier, up to a total of (amount of the guarantee in words and figures), and we undertake to pay you, upon your first written demand declaring the supplier to be in default under the contract and without cavil or argument, any sum or sums within the limits of (amount of guarantee) as aforesaid, without your needing to prove or to show grounds or reasons for your demand or the sum specified therein.

We hereby waive the necessity of your demanding the said debt from the supplier before presenting us with the demand. We further agree that no change or addition to or other modification of the terms of the contract to be performed thereunder or of any of the contract documents which may be made between you and the supplier shall in any way release us from any liability under this guarantee and we hereby waive notice of any such change, addition or modification.

We undertake to pay Bank Note Paper Mill India Private Limited up to the above amount upon receipt of its first written demand, without Bank Note Paper Mill India Private Limited having to substantiate its demand.

This guarantee will remain in force for a period of sixty days after the currency of this contract and any demand in respect thereof should reach the Bank not later than the above date.

.....
(Signature of the authorized officer of the Bank)
Name, authorisation/ signature no. and designation of the officer
Seal, name & address of the Bank and address of the Branch



CF

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

SECTION: XVI

CONTRACT FORM

SHEET 1 OF 1

NOT APPLICABLE TO THIS TENDER DOCUMENT



	BANK NOTE PAPER MILL INDIA PRIVATE LIMITED	SECTION: XVII
LOA	LETTER OF AUTHORITY FOR ATTENDING A BID OPENING	SHEET 1 OF 1

NOT APPLICABLE TO THIS TENDER DOCUMENT



SA

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

SECTION: XVIII

SHIPPING ARRANGEMENTS FOR LINER CARGOES

SHEET 1 OF 1

NOT APPLICABLE TO THIS TENDER DOCUMENT



PB

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED

SECTION: XIX

PROFORMA OF BILLS FOR PAYMENTS

SHEET 1 OF 1

NOT APPLICABLE TO THIS TENDER DOCUMENT



APQ	BANK NOTE INDIA PAPER MILL PRIVATE LIMITED	SECTION: XX
	APPLICATION- PRE-QUALIFICATION	SHEET 1 OF 5

**Instructions to the Applicants for Furnishing Information
As A Part of Pre-Qualifications Tender Notice**

1. Intending applicants are required to upload their full bio-data giving details about their organization, location of manufacturing units, experience, technical personnel in their organization, spare capacity competence and adequate evidence of their financial standing etc. in the enclosed format which will be kept confidential.
2. While deciding upon the selection of firms, great emphasis will be given on the ability and competence of applicants to do good quality works within the specified time schedule and in close coordination with other agencies, besides the rate structure of the items.
3. The application shall be signed by person / persons on behalf of the organization having necessary authorization / Power of Attorney to do so.
4. If the space in the proforma is insufficient for furnishing full details, such information may be supplemented on separate sheets of paper stating therein the part of the proforma and serial number. Separate sheets shall be used for each part.
5. Applications containing false and /or inadequate information are liable for rejection.



APQ	BANK NOTE INDIA PAPER MILL PRIVATE LIMITED	SECTION: XX
	APPLICATION- PRE-QUALIFICATION	SHEET 2 OF 5

To:

Managing Director
 Bank Note Paper Mill India Private Limited
 Administrative Building, Entry Gate 1,
 Paper Mill Compound,
 Note Mudran Nagar,
 Mysore - 570003

I / We have read and understood the Pre-qualification tender notice and instructions to the applicants and apply herewith for pre-qualification. . I / We furnish the information in the prescribed format including supplementary sheets fromfor your consideration. I/We do declare that the information furnished is correct and true to the best of my/our knowledge and belief.

Yours faithfully

Signature _____

Name: _____

Designation _____

Address _____

Seal _____



BASIC INFORMATION

1	Name of the applicant / organization and address of the registered office/business office.	
2	(a) Whether bidder is OEM (b) Address of the manufacturing facility in India (c) Annual Capacity of manufacturing facility	Yes / No
3	Type of the organization (whether Sole Proprietorship / Partnership / Private Limited / Limited or Cooperative Body etc).	
4	Name of the Proprietor / Partners / Directors of the Organization / Firm as the case may be.	(a) (b) (C)
5	Details of Registration – (whether Partnership firm, Company etc) – Name of Registering Authority, Date, Registration No etc.	
6	Whether registered with Government / Semi-Government / Municipal Authorities or any other Public Organization as a vendor and if yes provide details thereof.	
7	Experience in the field (Enclose documentary evidence)	_____ Years
8	Address of office through which the proposed work will be handled and the name and designation of the Officer-in-charge.	
9	Names of Bankers and their full addresses	
10	Whether any civil suit / litigation arisen in the contracts executed during the last five years / being executed now. If yes, please furnish the details in the proforma given below.	

Sl. No	Name of the project and employer	Nature of work	PO No. /Agreement No with date	Present stage of work	Value of contract	Brief details of litigation
1						
2						
3						
4						

11. Details of Similar supply completed during last five years ending 31.12.2017.
Number of supplementary sheets attached.

Sl No	Description of work including the capacity of the equipment	Name & Address of Customer	PO No. /Agreement No with date	Qty of supply	Delivery period
1					
2					
3					
4					
5					

(Enclose the Customer certificate/Documentary evidence duly attested by authorised signatory)

12. Financial Details

Sl No	Financial Year	Average Annual Turn Over (Rs)	Profit (Rs)	Loss (Rs)
1	2016-17			
2	2015-16			
3	2014-15			

(Enclose the certified/Audited copy of Profit and loss Account and Balance sheet as documentary evidence)

13. Has the applicant been blacklisted/ debarred by BNPMIPL/ BRBNMPL /SPMCIL or any Govt. Departments. Yes/NO
(If yes please provide the details.)

APQ	BANK NOTE INDIA PAPER MILL PRIVATE LIMITED	SECTION: XX
	APPLICATION- PRE-QUALIFICATION	SHEET 5 OF 5

14. Declaration on the Firm/company/proprietor, if it is closely related to director of the BNPM Yes/No

Signature of the Applicant _____

Name-----

Designation-----

Date-----

Stamp of the Organization-----



APQ	BANK NOTE INDIA PAPER MILL PRIVATE LIMITED	SECTION: XX
	DECLARATION	ANNEXURE- I SHEET 1 OF 1

Tender No: BNPM/TEN/LT PANEL/379/2017-18 dated 29.01.2018

(To be submitted on the letterhead)

DECLARATION

We do hereby declare that we have not been blacklisted/ debarred by BNPMIPL/ BRBNMPL /SPMCIL or any Govt. Departments. The information provided above is correct and true to the best of my knowledge and belief. In case, at any time the information furnished is found to be false, you may disqualify/debar me/us as deemed fit.

Signature _____

Name-----

Designation-----

Date-----

Stamp of the Organization-----



APQ	BANK NOTE INDIA PAPER MILL PRIVATE LIMITED	SECTION: XX
	DECLARATION	ANNEXURE- I SHEET 1 OF 1

Tender No: BNPM/TEN/LT PANEL/379/2017-18 dated 29.01.2018

(To be submitted on the letterhead)

DECLARATION

We do hereby declare that we have read and understood all terms and conditions of tender document including GIT, SIT, GCC, SCC, Technical Specification, Quality Control Criteria and confirm to abide to those conditions without any counter conditions.

Signature _____

Name-----

Designation-----

Date-----

Stamp of the Organization-----



Sl No	Description	Requirements of BNPMIPL, Terms & conditions	Ehether agreed by the firm (Yes/No)	Deviation if any
1.	General specifications	Items should be supplied exactly as per the given specifications mentioned in Section VII of the tender and have enclosed catalogue/brochure of the offered item	Yes/No	
2.	Quantity:	As per tender	Yes/No	
3.	Replacement of Rejection of materials	In case of rejection of material supplier shall replace the rejected material within 15 days on his cost	Yes/No	
4.	Delivery terms	As per section -VI	Yes/No	
5.	Payment terms	Payment terms as mentioned in the tender	Yes/No	
6.	Liquidated Damage	Liquidated Damage clause as mentioned in tender	Yes/No	
7.	Warranty	The items should be warranted against defects in material, design, workmanship etc. for a minimum period of 12 months from the date of supply and acceptance. During warranty period, the item should be replaced free of cost at our Store.	Yes/No	

8.	Tender terms & conditions	We have gone through entire tender document thoroughly including GIT (Section II - General Instructions to Tenderer), SIT (Section III - Special Instructions to Tenderer), GCC (Section IV - General Conditions Of Contract), and SCC (Section V - Special conditions of contract) and confirm that we don't have counter conditions. We also understand that offer with counter conditions is liable for rejection	Yes/No	
9.	Customer Certificate/Documentary evidence in support of Technical pre-qualification criteria (Duly certified by signatory authority)	Purchase Order/ Work Order/ Agreement/ work completion certificate	Submitted/ Not submitted	
10.	Certified Copy of Audited Balance Sheet and Profit & loss accounts	FY 2016-17 FY 2015-16 FY 2014-15	Submitted/ Not submitted	
11.	Declaration	Declaration that firm is not debarred/blacklisted	Submitted/ Not submitted	

12.	Performance security / Security Deposit	As per tender	Yes/ No	
13.	Enviro-friendly Packing of Product	The product/item to be supplied should be packed in an environment- friendly manner	Yes / No	

Signature

Name-----

Designation-----

Date-----

Stamp of the Organization-----

ACW

BANK NOTE INDIA PAPER MILL PRIVATE LIMITED

SECTION XXI

ADDITIONAL CONDITIONS OF WORKS CONTRACT

SHEET 1 OF 1

NOT APPLICABLE TO THIS TENDER DOCUMENT



IP

BANK NOTE INDIA PAPER MILL PRIVATE LIMITED

ANNEXURE- XXII

INTEGRITY PACT

SHEET 1 OF 1

NOT APPLICABLE TO THIS TENDER DOCUMENT

