

BANK NOTE PAPER MILL INDIA PRIVATE LIMITED,
CIN: U21090KA2010PTC055475
CORPORATE OFFICE, MYSORE
Email: bhoodhar@bnpmindia.com
Tel: 0821-2401-174

ENQUIRY No: BNPM/ENQ/ JUMBO DISPLAY/341/2017-18

Start Date: 27.12.2017

END Date: 02.01.2018

1. Scope of work:

Supply of “**Field Mounted, single side, jumbo display indicator**”.

2. Terms & Conditions:

S. No.	Particulars	Quantity
1.	Payment Terms	100% on receipt and acceptance of goods by the consignee at destination and on production of all required documents by the supplier. <u>NEFT/RTGS details shall be furnished along with invoice.</u>
2.	Price	Price should be inclusive of all taxes & duties.
3.	Freight	Shall be included in quoted price
4.	Packing & Forwarding	Shall be included in quoted price
5.	Delivery Terms	DAP, Bank Note Paper Mill India Private Limited, Mysore
6.	Warranty Period(Please specify)
7.	Warranty Certificate	Applicable/ Not Applicable
8.	Delivery Period(Please specify)
9.	Material to be delivered at	Engineering Stores Bank Note Paper Mill India Private Limited Note Mudran Nagar Mysore 570 003
Remarks: Quotation should send by mail to bhoodhar@bnpmindia.com .		



3. Price Bid Format :

S. No.	Description	Qty. A	UOM B	Unit rate C	GST @.....% D	Total E=C+D	Grand Total F=E*A
1	Field Mounted, single side, jumbo display indicator Specification as per Annexure-1	1	NOS				
						Grand Total	
Grand Total In Words:							

We hereby confirm that

1. We accept all terms & conditions mentioned in the enquiry.
Price quoted is inclusive of all taxes, duties, P&F, freight etc. on DAP, BNPM, Mysore basis.

Signature of bidder:

Name of the Firm:

Seal of the firm:



ANNEXURE-1-SPECIFICATION

ENQUIRY No: BNPM/ENQ/ JUMBO DISPLAY/341/2017-18 dt. 27.12.2017

Sr. No	Technical Specification	BNPM Requirements	Bidders offers	Deviation if any	Remakes
1.	Material	Single side, Jumbo Display , process indicator			
2.	Type	Microprocessor / Microcontroller based			
3.	Configuration/ program	Through front facia keys			
4.	Input type	4-20mA DC current or Universal input (Configurable)			
5.	DC excitation voltage	24V DC required			
6.	Display	7- Segment , 4-digit, 4 ½", RED LED display			
7.	Decimal point position	Configurable			
8.	Accuracy	±1% of FSD			
9.	Relay output	2 NO +2NC required (configurable high/low alarms)			
10.	Relay rating	230VDC, 5A (resistive)			
11.	Enclosure materials	Metallic			
12.	Ingress protection class	IP65 for front facia			
13.	Power supply	90-270VAC, 50Hz universal power supply			
14.	Dimensions	160mm(H) x 380mm(W) x 50 mm(D) or nearest equivalent			
15.	Mounting	Wall mounted			
16.	Mounting Accessories	Required			
17.	Diagnostics Messages	Process overflow, process underflow and sensor break			
18.	Ambient Temperature	0-55 Deg.C			
19.	Relativity Humidity	Upto 95% Non-Condensing			

