



बैंक नोट पेपर मिल इण्डिया प्रा. लिमिटेड

BANK NOTE PAPER MILL INDIA PVT LIMITED

JV of SPMCIL - A Govt. of India Enterprises & BRBNMPL - A Subsidiary of RBI

email : scmcommon@bnpmindia.com, Ph: 0821 2401 178

Limited Tender Enquiry No: BNPM/LTE/Temp Controller & Sensor/324/2018-19

Enquiry date: 16.07.2018

Closing Date: 20.07.2018 @ 1100 Hrs

1. Scope of work:

Supply of **Temperature controller & sensor.**

2. Terms & Conditions:

S. No.	Particulars	Quantity
1.	Payment Terms	100% on receipt and acceptance of goods by the consignee at destination and on production of all required documents by the supplier. <u>Warranty certificate (if applicable) and NEFT/RTGS details shall be furnished along with invoice.</u>
2.	Price	Price should be inclusive of taxes,
3.	Freight	Shall be included in quoted price
4.	Packing & Forwarding	Shall be included in quoted price
5.	Delivery Terms	DAP, Bank Note Paper Mill India Private Limited, Mysore
6.	Warranty Period
7.	Warranty Certificate	Applicable / Not Applicable
8.	Delivery Period
9.	Material to be delivered at	Engineering Stores Bank Note Paper Mill India Private Limited Note Mudran Nagar Mysore 570 003
10.	Contact person in Engineering Stores	Mr. N.Saideep 0821-2401178 Scmcommon@bnpmindia.com



Price Bid Format:

S. No.	Description	Qty.	UOM	Unit rate	Freight, P&F Charges	GST@	Unit rate including GST & Freight, P&F Charges	Grand total inclusive of GST and Freight, P&F Charges (DAP, BNPM, Mysore)
1.	Temperature controller with Display	06	Nos					
2.	Temperature sensor	06	Nos					
Total price inclusive of all tax, freight , P&F charges								

Technical Specifications:-

S.No	Tech Description
01	Temperature Controller with digital display
	Input sensor type: Thermocouple, RTD, linear voltage/ current input (4-20mA)
	Relay Outputs; 230V AC/ 24VDC
	For ON/OFF control and current output (4-20mA) for remote PLC/DCS
	Range: 0-100° C
	Preferable Makes: Delta DTB 4848 Any other reputed make on subject to the acceptance of technical specifications

S.No	Tech Description
02	Temperature Sensor
	RTD Sensor, PT 100 with flexible cable, Range: 0-100° C
	Type: Pt100 3 wire spring loaded assembly
	No of elements: Two (duplex) pt 100 x2; Response time: 10sec
	Accuracy- Class A as per IEC 751/ DIN EN60751
	Application: Immersed in water tank
	Flexible wire length connected to probe bulb: 750mm
	Probe bulb length: 75 to 100mm; Bulb dia: 10mm



	The sensor will be connected to mostly delta temperature controller model DTB4848.
	Test certificates/ Calibration reports to be supplied.
	Preferred Makes: GIC/ Pyro electric Instruments/ Altop controls/ Ashcroft India Pvt Ltd/ Electrical & Electronics Corp/ Wika.

We hereby confirm that

1. We accept all terms & conditions mentioned in the enquiry.
2. Price quoted is inclusive of all taxes, P&F, freight etc. on DAP, BNPM, Mysore basis.
3. HSN Code:

Signature of bidder:.....

Name of the Firm:.....

Seal of the firm:

GST No:

