

TEST REPORT

Address of the Customer:

M/s.Bank Note Paper Mill India Pvt.Ltd.
Note Mudran Nagar
Mysore- 570 003.

Report No. : WWD/2018/07/0443
Date of Receipt : 24/07/2018
Date of Analysis : 24/07/2018
Date of Completion: 30/07/2018
Date of Report : 30/07/2018
Job Order No. : WWD/2018/07/0443
Sampling Type : Grab
Sampling Point : After Filtration Tank
Your Reference : Verbal

Sample Particulars : ETP Treated water

Date of Sampling : 24/07/2018

Sample Qty. : 2Ltrs

Sample Marked : N.S

Sample Description : Colourless liquid having unobjectionable odor.

Sl. No.	Tests	Unit	Results	Tolerance Limits	Test Method
Chemical Test					
1	Colour	Hazen units	<5.0(BDL)	See Note	IS3025(Part-4):1983
2	Odor	----	Unobjectionable	See Note	IS3025(Part-5):1983
3	Total Suspended Solids	mg/L	<1.0(BDL)	100 max	IS3025(Part-17):1996(Reaff:2012)
4	pH Value	----	7.6	6.5-8.0	IS3025(Part-11):1983(Reaff:2012)
5	Oil & Grease	mg/L	<1.0(BDL)	10 max	IS3025(Part-39):1991(Reaff:2009)
6	Biochemical Oxygen Demand,5Days@20°C	mg/L	2.0	30 max	IS3025(Part-44):1993(Reaff:2009)
7	Chemical Oxygen Demand as O2	mg/L	7.0	250 max	IS3025(Part-58):2006(Reaff:2012)

Note:

- 1)Sample preserved@2-8°C,2)N.S:Not Specified,3)BDL:Below Detection Limit.
- 4)All efforts should be made to remove color and unpleasant odor as far as practicable.

Tested by *Chemist Sushmita*



Authorised Signatory

Note 1. The results listed above pertain only to the tested samples and applicable parameters. 2. Samples will be stored for a period of one month unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and can not be used an evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us, unless specified.