



ग्लोबल इन्फोर्मेशन

## TEST REPORT

**Address of the Customer:**

M/s.Bank Note Paper Mill India Pvt.Ltd.  
Note Mudran Nagar  
Mysore- 570 003.

Report No. : WWD/2018/06/0302  
Date of Receipt : 15/06/2018  
Date of Analysis : 15/06/2018  
Date of Completion: 21/06/2018  
Date of Report : 21/06/2018  
Job Order No. : WWD/2018/06/0302  
Sampling Type : Grab  
Sampling Point : Gardening Water Tank  
Your Reference : Verbal

Sample Particulars : ETP Treated water

Date of Sampling : 15/06/2018  
Sample Qty. : 2Ltrs  
Sample Marked : N.S

Sample Description : Colourless liquid having unobjectionable odor.

Sl. No.	Tests	Unit	Results	Tolerance Limits	Test Method
Chemical Test					
1	Colour	Hazen units	<5.0(BDL)	See Note	IS3025(Part-4):1983
2	Odor	----	Unobjectionable	See Note	IS3025(Part-5):1983
3	Total Suspended Solids	mg/L	2.0	100 max	IS3025(Part-17):1996(Reaff:2012)
4	pH Value	----	7.6	6.5-8.0	IS3025(Part-11):1983(Reaff:2012)
5	Oil & Grease	mg/L	<1.0(BDL)	10 max	IS3025(Part-39):1991(Reaff:2009)
6	Biochemical Oxygen Demand,5Days@20°C	mg/L	4.0	30 max	IS3025(Part-44):1993(Reaff:2009)
7	Chemical Oxygen Demand as O <sub>2</sub>	mg/L	13.0	250 max	IS3025(Part-58):2006(Reaff:2012)

Note:

- 1)Sample preserved@2-8°C,2)N.S:Not Specified,3)BDL:Below Detection Limit.
- 4)All efforts should be made to remove color and unpleasant odor as far as practicable.

Tested by *Suk*  
Chemist: *Sukmaha*

*[Signature]*  
Sr.Chemist  
Authorised Signatory

Note 1. The results listed above pertain only to the tested samples and applicable parameters. 2. Samples will be stored for a period of one month unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and can not be used as evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us, unless specifically requested.